

Certificate of compliance

with the order 2.1 according to EN 10 204

HELUTHERM® 120

We confirm that the above mentioned **PVC control and connection cable** is produced **in alignment with DIN VDE 0285-525-2-11 / DIN EN 50525-2-11** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

| | |
|--------------------------|--|
| Temperature range | flexible -5°C to +105°C fixed -30°C to +105°C |
| Nominal voltage | 0.5 - 1 mm ² : AC U ₀ /U 300/500 V 1.5 - 4 mm ² : AC U ₀ /U 450/750 V |

TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2
certifications and approvals:
EAC

PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

HELU KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
26.08.2022

Date of expiration
31.12.2023

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helukabel.com

HELU KABEL GmbH
Headquarters
Schloßhaldenstraße 10
71282 Hemmingen
Germany